



Jim Doyle, Governor
Mary P. Burke, Secretary

September 13, 2004

USA MODULAR
DAN SCALISE
7195N 1150W
SHIPSHEWANA IN 46565

WHITLEY MANUFACTURING
DAN SCALISE
201 W FIRST ST
PO BOX 496
SOUTH WHITLEY IN 46787

Re: Description: PREFABRICATED PLUMBING SYSTEM
Manufacturer: WHITLEY MANUFACTURING
Product Name: MODULAR CLASSROOM
Model Number(s): 6095 (BUILDING); JRH6095S (SUPPLY WATER); JRH6095DWV (DRAIN,WASTE,VENT)
Product File No: 20040478

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of September 2009.

This approval is contingent upon compliance with the following stipulation(s):

- The flowing water supply pressure at the point(s) of connection must be at least 39 psig.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.

A copy of the approved plans and/or specifications is enclosed.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Michael J. Beckwith, CIPE
Plumbing Product Reviewer
phone: 608-266-6742
fax: 608-267-9566
e-mail: mike.beckwith@wi.gov